



Formerly P.C. Simonton & Associates, Inc.

MEMORANDUM

August 11, 2020

TO: All Bidders

FROM: Elliott Wilson *EW*

RE: Tower Street Reconstruction
City of Folkston
MES No. 2019-120

The purpose of this memo is to provide clarification on the following questions:

1. The bid item list indicates 3 ADA ramps. The drawing only shows 1.
 - The drawing shows 4 Type-D ADA ramps (typ), however, the ADA ramp on the Western intersection of the sidewalk and Love Street was removed and replaced with a detectable warning surface due to the lack of curb and gutter. See Addendum 2 for clarification.

