



Formerly P.C. Simonton & Associates, Inc.

MEMORANDUM

August 17, 2020

TO: All Bidders

FROM: Elliott Wilson *EW*

RE: Tower Street Reconstruction
City of Folkston
MES No. 2019-120

The purpose of this memo is to provide clarification on the following questions:

1. Is the striping paint or thermo?
Answer: Road centerline, edge markings, and crosswalk shall be thermo. Parking areas shall be paint.