



Formerly P.C. Simonton & Associates, Inc.

## Addendum No. Three

Date: August 4, 2021  
Project: Pembroke Sewer Rehabilitation, MES No. 2017-89  
Engineer: M.E. Sack Engineering  
Hinesville, Georgia

The original plans, specifications, and bid documents are amended to include the following:

Clarifications:

- Replace the previous Clarification #6 from Addendum Two with the answer below:

6. *Does the cleaning of the lines require disinfectant?*

No. Specification 02660, section 3.03 DISINFECTION identifies is intended for water lines, not sewer lines, and is not applicable to this project.

-END-

