



515 N. Main Street | Hinesville, GA 31313  
PO Box 649 | Hinesville, GA 31310  
912.368.5212  
www.mesack.com  
ME Sack Engineering  
@mesackengineering  
mesack



## MEMORANDUM

DATE: September 7, 2022  
TO: All Bidders  
FROM: Elliott Wilson, PM *EW*  
RE: 2022 LMIG  
For City of Pembroke  
MES No. 2021-83

The purpose of this memo is to provide clarification on the following question:

- 1) *Please define the thickness of the crack proof layer (OGI) as requested in the proposal.*
  - The thickness of the crack proof layer (OGI) shall be one (1) inch. See GDOT Section 415.